

Company:	Owner:		
Address:	Date:		
Phone:			

NEW		RENEWAL		
General	Pass	Fail	Comments	
Address is posted and visible from street side.				
Two exits provided from each floor used and unobstructed. One may be an escape window if occupant load is 8 or less and the window meets the escape window requirements.				
Housekeeping is in good order.				
Proper storage of hazardous materials and flammable liquids and gasses.				
Furnace is in good condition, properly vented and provided with adequate combustion air.				
Unvented heaters contain oxygen depletion sensitive safety shutoff devices and are free of combustible materials.				
All heating devices are screened or otherwise protected. Open flame remote from combustibles.				
Electrical wiring, switches, and fixtures are in good condition and covered.				
Electrical outlets are provided with child protective covers.				
Electrical panels are accessible. (Minimum 30" clearance)				
Electrical panels are properly covered & latched.				
Proper use of extension cord. (i.e. temporary use for special occasion)				
All wiring is either enclosed or in conduit.				
Adequate smoke detectors are provided and in good condition as required by the Uniform Fire Code or Certificate of Occupancy (most restrictive).				
Fire extinguisher (minimum 2A:10BC) provided, annually inspected; and properly mounted. One on each floor occupied by clients.				
Comments:				
Fire Department Personnel	Signatu	ıre of Reci	pient	

APPROVED DENIED

Agency listed under _____